

Software: Stroma U-value Calculator - Version 0.92
 Date Printed: 17/01/2023 16:43
 Construction Type: Wall - 125 - 6 Inch - 100 Clad
 Calculation Method: BS EN ISO 6946

Wall Construction

No	Description	Main Element			Bridging Element		
		Thickness	λ	R-value	λ	R-value	Fraction
-	Internal Surface Resistance	-	-	0.13	-	-	-
1	Plaster (Lightweight)	3	0.18	0.017	-	-	-
2	Plasterboard Standard	12.5	0.21	0.06	-	-	-
3	XPS	125	0.03	4.167	-	-	-
4	Concrete	150	1.93	0.078	0.88	0.17	0.0667
5	XPS	100	0.03	3.333	-	-	-
6	Battens (25 mm)	25	-	0.18	0.13	0.192	0.095
7	Cladding	18	0.13	0.138	-	-	-
-	External Surface Resistance	-	-	0.04	-	-	-
		$\Sigma=433.5\text{mm}$		$\Sigma=8.142$			

Resistances

Lower Limit	Upper Limit	Average
8.146	8.15	8.148 m ² K/W

Wall U-value Corrections

No Correction Values

Wall U-value

U-value	0.123
U-value rounded	0.12 W/m ² K